

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of October 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Hrs:Min			
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400/220 KV ICT-2 at Patran	30/10/2023 16:01	30/10/2023 18:45	2:44	0:00	0:00	0:00	0:00	Emergency shutdown taken by PTCL for SF6 gas refilling works.	99.94%	
400KV Kaithal -Patran-1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400KV Kaithal -Patran-2			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400KV Patiala-Patran-2			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400/220 KV ICT-1 at Patran			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400KV Patiala-Patran-1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		

Patran Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of October 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of October 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL