

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of September 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400KV Patiala-Patran-1	23/09/2023 12:04	23/09/2023 19:00	6:56	0:00	0:00	0:00	Emergency shutdown taken by PTCL to check leakage point and refill the SF6 gas in B6 compartment 400kV D/C Patran-Patiala Ckt-01	99.84%
400KV Kaithal -Patran-1	01/09/2023 12:36	01/09/2023 15:52	0:00	0:00	0:00	3:16	Emergency shutdown was taken by the PGCIL for rectification of damaged conductor at Loc no 34-35 Top phase. Only 100.0Mtrs of LILO portion is under the ownership of PTCL.	
400KV Kaithal -Patran-2			0:00	0:00	0:00	0:00	No Tripping/outage in this month	
400KV Patiala-Patran-2			0:00	0:00	0:00	0:00	No Tripping/outage in this month	
400/220 KV ICT-1 at Patran			0:00	0:00	0:00	0:00	No Tripping/outage in this month	
400/220 KV ICT-2 at Patran			0:00	0:00	0:00	0:00	No Tripping/outage in this month	

**Patran Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of September 2023**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL