

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of August 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Hrs:Min			
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400kV Parbati 3 - Sainj HEP	21/08/2023 16:31	21/08/2023 17:15	0:00	0:00	0:00	0:44	0:44	Emergency Shutdown taken by NHPC for overhauling to Discharge the Bus-2 and to Charge Bus-1 CB	100.00%	
400kV Parbati 3-400kV Banala Pooling Station	21/08/2023 12:57	21/08/2023 20:07	0:00	0:00	0:00	7:10	7:10	Emergency shutdown availed by the PGCIL to attend the Snapping of Jumper De-capped insulator at loc no. 07 in Y-Ph of PGCIL line. Only 3.158Kms belongs to PKTCL, shutdown was taken at PGCIL portion.		
400kV Koldam-Ludhiana Ckt 1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400kV Koldam-Ludhiana Ckt 2			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400 KV Nallagarh(PG)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400 KV Koldam(NT)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400 KV Parbati 2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		
400 KV Parbati 2(NH)-Sainj(HP) (PKTCL) Ckt-1			0:00	0:00	0:00	0:00	0:00	No Tripping/outage in this month		

Parbati Koldam Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL