

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of February 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to			Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available			
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min			
400 KV Koldam(NT)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	04-02-2024 16:12	04-02-2024 19:31	3:19	0:00	0:00	0:00	Line tripped on R phase to Y phase fault.		
400kV Koldam-Ludhiana Ckt 1	01-02-2024 00:00	01-02-2024 06:46	0:00	0:00	0:00	6:46	Continuous under outage since previous month. Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	01-02-2024 22:34	02-02-2024 06:31	0:00	0:00	0:00	7:57	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	02-02-2024 23:30	03-02-2024 06:29	0:00	0:00	0:00	6:59	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	03-02-2024 23:16	04-02-2024 06:18	0:00:00	0:00:00	0:00:00	7:02:00	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	04-02-2024 21:20	05-02-2024 06:03	0:00:00	0:00:00	0:00:00	8:43:00	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	05/02/2024 22:02	06/02/2024 05:53	0:00	0:00	0:00	7:51	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	10/02/2024 02:25	10/02/2024 06:08	0:00	0:00	0:00	3:43	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	10/02/2024 21:53	11/02/2024 06:18	0:00	0:00	0:00	8:25	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	11/02/2024 21:29	12/02/2024 05:57	0:00	0:00	0:00	8:28	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	13/02/2024 21:58	14/02/2024 06:17	0:00	0:00	0:00	8:19	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	14/02/2024 21:37	15/02/2024 05:25	0:00	0:00	0:00	7:48	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	15/02/2024 21:51	16/02/2024 05:46	0:00	0:00	0:00	7:55	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	17/02/2024 01:02	17/02/2024 05:50	0:00	0:00	0:00	4:48	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	18/02/2024 21:33	19/02/2024 05:52	0:00	0:00	0:00	8:19	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	19/02/2024 21:24	20/02/2024 06:19	0:00	0:00	0:00	8:55	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	20/02/2024 22:00	21/02/2024 05:38	0:00	0:00	0:00	7:38	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	21/02/2024 22:11	22/02/2024 06:32	0:00	0:00	0:00	8:21	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	24/02/2024 23:55	25/02/2024 05:20	0:00	0:00	0:00	5:25	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	27/02/2024 22:39	28/02/2024 06:00	0:00	0:00	0:00	7:21	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 2	28/02/2024 22:15	29/02/2024 05:45	0:00	0:00	0:00	7:30	Line was hand tripped as per RLDC instruction due to Voltage Regulation.		
400kV Koldam-Ludhiana Ckt 1	29/02/2024 21:25	01/03/2024 00:00	0:00	0:00	0:00	2:35	Line was hand tripped as per RLDC instruction due to Voltage Regulation. Still not charged in this month.		

Parbati Koldam Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of February 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of February 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL