

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of January 2024

Schedule I

Element Name	Outage		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Koldam-Ludhiana Ckt 1	09-01-2024 12:33	09-01-2024 19:06	0:00	0:00	0:00	6:33	Shutdown availed by CPCC Jammu for Line Equipment AMP WORKS OF 400 KV Ludhiana-Koldam Ckt -1 at Ludhiana. Only Line Portion belongs to PrKTCL.	
400kV Koldam-Ludhiana Ckt 2	10-01-2024 11:55	10-01-2024 19:18	0:00	0:00	0:00	7:23	Shutdown availed by CPCC Jammu for Line Equipment AMP WORKS OF 400 KV Ludhiana-Koldam Ckt -2 at Ludhiana. Only Line Portion belongs to PrKTCL.	
400kV Koldam-Ludhiana Ckt 2	10-01-2024 20:16	12-01-2024 12:44	0:00	0:00	0:00	40:28	Emergency Shutdown Availed by Koldam for Breaker Alignment due to pole discrepancy. Only Line Portion belongs to PrKTCL.	
400 KV Koldam(NT)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	10-01-2024 20:29	11-01-2024 01:59	0:00	5:30	0:00	0:00	Koldam substation blackout due to Failure of CB Koldam Banala line at Koldam substation.	
400kV Koldam-Ludhiana Ckt 1	10-01-2024 20:29	11-01-2024 03:34	0:00:00	7:05:00	0:00:00	0:00:00	Koldam substation blackout due to Failure of CB Koldam Banala line at Koldam substation.	
400kV Koldam-Ludhiana Ckt 2	26-01-2024 19:19	26-01-2024 20:15	0:00:00	0:56:00	0:00:00	0:00:00	Line tripped from Koldam end due to low pressure in Main CB & A/R Successful from Ludhiana end due to B-Phase to earth fault.( FIR Created for A/R)	
400kV Koldam-Ludhiana Ckt 2	01/01/2024 00:00	01/01/2024 05:36	0:00	0:00	0:00	5:36	Continuous under outage since previous month. Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	01/01/2024 22:31	02/01/2024 05:30	0:00	0:00	0:00	6:59	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	06/01/2024 23:02	07/01/2024 06:00	0:00	0:00	0:00	6:58	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	08/01/2024 00:25	08/01/2024 07:00	0:00	0:00	0:00	6:35	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	09/01/2024 01:29	09/01/2024 06:33	0:00	0:00	0:00	5:04	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	09/01/2024 21:52	10/01/2024 06:40	0:00	0:00	0:00	8:48	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	11/01/2024 03:34	11/01/2024 05:29	0:00	0:00	0:00	1:55	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	12/01/2024 23:00	13/01/2024 05:48	0:00	0:00	0:00	6:48	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	13/01/2024 21:47	14/01/2024 05:45	0:00	0:00	0:00	7:58	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	14/01/2024 21:46	15/01/2024 05:25	0:00	0:00	0:00	7:39	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	16/01/2024 00:08	16/01/2024 06:35	0:00	0:00	0:00	6:27	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	16/01/2024 23:00	17/01/2024 06:34	0:00	0:00	0:00	7:34	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	17/01/2024 22:57	18/01/2024 06:23	0:00	0:00	0:00	7:26	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	19/01/2024 00:51	19/01/2024 05:56	0:00	0:00	0:00	5:05	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	24/01/2024 00:36	24/01/2024 05:33	0:00	0:00	0:00	4:57	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	24/01/2024 22:26	25/01/2024 05:41	0:00	0:00	0:00	7:15	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	25/01/2024 22:15	26/01/2024 06:11	0:00	0:00	0:00	7:56	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	26/01/2024 22:24	27/01/2024 06:08	0:00	0:00	0:00	7:44	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	31/01/2024 01:00	31/01/2024 06:18	0:00	0:00	0:00	5:18	Line was hand tripped as per RLDC instruction due to Voltage Regulation. The line outage continued for the month.	
400kV Koldam-Ludhiana Ckt 1	31/01/2024 22:13	01/02/2024 00:00	0:00	0:00	0:00	1:47	Line was hand tripped as per RLDC instruction due to Voltage Regulation. The line outage continued for the month.	

**Parbati Koldam Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of January 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of January 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL