

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of November 2023

Schedule I

Element Name	Outage		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 KV Parbati_2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	04-11-2023 20:50	04-11-2023 21:44	0:00	0:00	0:00	0:54	Shutdown availed by PowerGrid for Relay Testing works at 400kV Banala Substation.	100%
400kV Koldam-Ludhiana Ckt 1	08-11-2023 11:11	08-11-2023 18:13	0:00	0:00	0:00	7:02	Failure of CVT Due to non availability of tie breaker of Koldam-Ludhiana ckt#1 and due to emergency CVT replacement of Koldam Bus#2 S/D availed by KOLDAM NT.	
400kV Koldam-Ludhiana Ckt 2	02-11-2023 01:36	02-11-2023 05:52	0:00	0:00	0:00	4:16	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	02-11-2023 23:24	03-11-2023 05:52	0:00	0:00	0:00	6:28	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	03-11-2023 23:22	04-11-2023 05:53	0:00:00	0:00:00	0:00:00	6:31:00	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	04-11-2023 22:59	05-11-2023 06:47	0:00:00	0:00:00	0:00:00	7:48:00	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	05/11/2023 22:28	06/11/2023 06:51	0:00	0:00	0:00	8:23	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	06/11/2023 21:35	07/11/2023 06:07	0:00	0:00	0:00	8:32	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	07/11/2023 22:01	08/11/2023 05:26	0:00	0:00	0:00	7:25	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	09/11/2023 00:33	09/11/2023 06:17	0:00	0:00	0:00	5:44	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	10/11/2023 00:46	10/11/2023 05:14	0:00	0:00	0:00	4:28	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	10/11/2023 21:37	11/11/2023 06:10	0:00	0:00	0:00	8:33	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	11/11/2023 23:51	12/11/2023 05:22	0:00	0:00	0:00	5:31	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	12/11/2023 13:44	12/11/2023 16:51	0:00	0:00	0:00	3:07	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	12/11/2023 22:01	13/11/2023 05:52	0:00	0:00	0:00	7:51	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	13/11/2023 21:23	14/11/2023 05:36	0:00	0:00	0:00	8:13	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	14/11/2023 22:15	15/11/2023 06:17	0:00	0:00	0:00	8:02	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	15/11/2023 21:39	16/11/2023 05:38	0:00	0:00	0:00	7:59	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	16/11/2023 22:48	17/11/2023 06:41	0:00	0:00	0:00	7:53	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	17/11/2023 22:22	18/11/2023 06:33	0:00	0:00	0:00	8:11	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	18/11/2023 21:53	19/11/2023 05:48	0:00	0:00	0:00	7:55	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	19/11/2023 21:23	20/11/2023 05:33	0:00	0:00	0:00	8:10	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	20/11/2023 23:45	21/11/2023 06:39	0:00	0:00	0:00	6:54	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	21/11/2023 22:14	22/11/2023 07:04	0:00	0:00	0:00	8:50	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	22/11/2023 22:05	23/11/2023 06:10	0:00	0:00	0:00	8:05	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	23/11/2023 21:34	24/11/2023 06:46	0:00	0:00	0:00	9:12	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	24/11/2023 21:22	25/11/2023 06:28	0:00	0:00	0:00	9:06	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	25/11/2023 20:32	26/11/2023 05:34	0:00	0:00	0:00	9:02	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	26/11/2023 21:14	27/11/2023 05:16	0:00	0:00	0:00	8:02	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	27/11/2023 21:34	28/11/2023 05:51	0:00	0:00	0:00	8:17	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	29/11/2023 00:02	29/11/2023 06:31	0:00	0:00	0:00	6:29	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	29/11/2023 23:57	30/11/2023 06:43	0:00	0:00	0:00	6:46	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	30/11/2023 21:31	01/12/2023 00:00	0:00	0:00	0:00	2:29	Line was hand tripped as per RLDC instruction due to Voltage Regulation. The line outage continued for the month.	

Parbati Koldam Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of November 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of November 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL