

Maheshwaram Transmission Limited

I. AC Transmission Line Outage Details for the month of December 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	05-12-2023	09:47:00	05-12-2023	11:05:00	0:00	1:18	0:00	0:00	MTL taken the Shutdown for diversion activities due to the construction of a pond by the Irrigation Department. The line was shut down at 09:47 AM. PTW (Permit to Work) for the same was issued at 11:05 AM due to unknown reason. Kindly please consider additional outage hours into other account. We have enclosed the email communication for your reference. Shutdown Code : 464 Charging Code :	100.00%
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	05-12-2023	11:05:00	07-12-2023	09:48:00	0:00	0:00	0:00	46:43	MTL taken the shutdown for AMP Work. PTW for the same was issued at 11:05Hrs. Charging clearance was given at 09:48Hrs and at 11:13Hrs CEA energination approval also submitted and charging code was received at 11:57 Hrs and line was finally charged at 13:11Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason enclosed here with the email copy. Shutdown Code : Charging Code :	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	07-12-2023	09:48:00	07-12-2023	13:11:00	0:00	3:23	0:00	0:00	MTL given the charging clearance at 09:48Hrs and at 11:13Hrs CEA energination approval also submitted and charging code was received at 11:57 Hrs and line was finally charged at 13:11Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason enclosed here with the email copy. Kindly please consider additional outage hours into other account. We have enclosed the email communication for your reference. Shutdown Code : Charging Code : 751	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	05-12-2023	09:54:00	05-12-2023	11:05:00	0:00	1:11	0:00	0:00	MTL taken the Shutdown for diversion activities due to the construction of a pond by the Irrigation Department. The line was shut down at 09:54 AM. PTW (Permit to Work) for the same was issued at 11:05 AM due to unknown reason. Kindly please consider additional outage hours into other account. We have enclosed the email communication for your reference. Shutdown Code : 465 Charging Code :	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	05-12-2023	11:05:00	07-12-2023	09:48:00	0:00	0:00	0:00	46:43	MTL taken the shutdown for AMP Work. PTW for the same was issued at 11:05Hrs. Charging clearance was given at 09:48Hrs and at 11:13Hrs CEA energination approval also submitted and charging code was received at 11:57 Hrs and line was finally charged at 13:16Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason enclosed here with the email copy. Shutdown Code : Charging Code :	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	07-12-2023	09:48:00	07-12-2023	13:16:00	0:00	3:28	0:00	0:00	MTL given the charging clearance at 09:48Hrs and at 11:13Hrs CEA energination approval also submitted and charging code was received at 11:57 Hrs and line was finally charged at 13:16Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason enclosed here with the email copy. Kindly please consider additional outage hours into other account. We have enclosed the email communication for your reference. Shutdown Code : Charging Code : 752	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	

Maheshwaram Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of December 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of December 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

