

Maheshwaram Transmission Limited

I. AC Transmission Line Outage Details for the month of July 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	100.00%
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2	20-07-2023	03:10:00	20-07-2023	07:07:00	0:00	0:00	3:57	0:00	Line tripped on over voltage protection. Charging Code - 2095 Voltage at Shankarapally during tripping on Overvoltage: -434kV Voltage at Nizamabad during tripping on Overvoltage: -428kV Voltage before line taken into service from Shankarapally: -420kV Voltage before line taken into service from Nizamabad: -418kV Also enclosed here with the SRLDC Analysis report.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2	27-07-2023	04:58:00	28-07-2023	10:30:00	0:00	0:00	29:32	0:00	Line tripped on over voltage protection. Charging Code - 2860 Voltage at Shankarapally during tripping on Overvoltage: -434kV Voltage at Nizamabad during tripping on Overvoltage: -426kV Voltage before line taken into service from Shankarapally: -418kV Voltage before line taken into service from Nizamabad: -416kV Also enclosed here with the SRLDC Analysis report.	

Maheshwaram Transmission Limited**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2023****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2023**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

