

**Maheshwaram Transmission Limited**

**I. AC Transmission Line Outage Details for the month of June 2023**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	100.00%
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	24-06-2023	21:28:00	30-06-2023	8:11:00	0:00	0:00	0:00	130:43	Line Hand Trip as per SRLDC Instruction due to volatge regulation Outage Code - 2682 Charging Code -3176 Voltage at Mehboob nagar during taking out of service: -435kV Voltage at Maheshwaram during taking out of service: -426kV Voltage before line taken into service from Mehboob nagar: -413kV Voltage before line taken into service from Maheshwaram: -410kV	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	

**Maheshwaram Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of June 2023**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

