

Maheshwaram Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	21-05-2023	19:36:00	21-05-2023	22:01:00	2:25	0:00	0:00	0:00	TSTRANSCO taken the emergency shutdown Due to heavy sparking in the Y-Phase Line isolator at Mehboobnagar substation. Outage Code - 2048 Charging Code -2055	99.93%
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	30-05-2023	14:27:00	30-05-2023	22:35:00	0:00	0:00	0:00	8:08	PGCIL taken the emergency shutdown for attending heavy spark in Y-Phase CVT at Maheswaran substation. Outage Code - 3081 Charging Code - 3161	
400kV Maheshwaram(PG)-Mehboob nagger(TS) Line-2					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2					0:00	0:00	0:00	0:00	No Tripping / outage in this month.	

Maheshwaram Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

