

Raichur Sholapur Transmission Company Private Limited

I. AC Transmission Line Outage Details for the month of April 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
RAICHUR - SHOLAPUR II	28-04-2023	15:27:00	29-04-2023	16:07:00	00:00:00	00:00:00	00:00:00	24:40:00	PGCIL Emergency hand trip the line from Raichur end due to line isolator was partially opened and heavy spark was observed between the arms and line isolator arm contacts got burnt. Enclosed here with the email communication for your reference. Charging Code - 3475	100.00%

Raichur Sholapur Transmission Company Private Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil