

Raichur Sholapur Transmission Company Private Limited

I. AC Transmission Line Outage Details for the month of July 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
RAICHUR - SHOLAPUR II	04-07-2023	21:22:00	04-07-2023	22:33:00	00:00:00	01:11:00	00:00:00	0:00:00	Line was in idle charged condition from Sholapur SS, A/R was successful from Sholapur SS and A/R was un-successful from Raichur SS due to carrier channel fail. Only line portion belongs to RSTCPL, terminal equipment of bay under the ownership of PGCIL. Hence outage is not accountable to RSTCPL. Charging Code - 410 Enclosed here with the SRLDC analysis report.	100.00%
RAICHUR - SHOLAPUR II	28-07-2023	11:43:00	28-07-2023	13:03:00	00:00:00	01:20:00	00:00:00	0:00:00	Line was in idle charged condition from Sholapur SS & tripped from Raichur end only due to DT Received from Solapur SS. Only line portion belongs to RSTCPL, terminal equipment of bay under the ownership of PGCIL. Hence outage is not accountable to RSTCPL. Charging Code - 2864 Enclosed here with the SRLDC analysis report.	

Raichur Sholapur Transmission Company Private Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil