

**Bhopal Dhule Transmission Company Limited**

**I. AC Transmission Line Outage Details for the month of April 2023**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765 KV Bus Reactor at BDTCL Dhule	03-04-2023	10:26:00	03-04-2023	20:15:00	0:00	0:00	0:00	9:49	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	99.94%
765 KV Bus Reactor at BDTCL Dhule	04-04-2023	08:28:00	04-04-2023	10:06:00	0:00	0:00	0:00	1:38	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	04-04-2023	10:30:00	04-04-2023	12:56:00	0:00	0:00	0:00	2:26	Shutdown taken for switching operation for taking the Spare Phase into service & Y-phase as a standby. As per CEA regulation to ensure hot spare healthiness, in every 6 months switching operation was carried out. As per 5400CC for reactor switching 3hrs period will be considered under deemed availability. No maintenance activity was done.	
765 KV Bus Reactor at BDTCL Dhule	05-04-2023	08:48:00	15-04-2023	18:52:00	0:00	0:00	0:00	250:04	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II	08-04-2023	17:26:00	08-04-2023	18:11:00	0:45	0:00	0:00	0:00	Line Tripped on Transient B-Phase to Earth Fault	
765 kv bus reactor at BDTCL Bhopal	12-04-2023	09:45:00	16-04-2023	18:38:00	0:00	0:00	0:00	104:53	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	17-04-2023	09:39:00	17-04-2023	19:22:00	0:00	0:00	0:00	9:43	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	18-04-2023	09:50:00	19-04-2023	19:34:00	0:00	0:00	0:00	33:44	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	20-04-2023	10:14:00	20-04-2023	18:25:00	0:00	0:00	0:00	8:11	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	24-04-2023	15:40:00	29-04-2023	02:35:00	0:00	0:00	0:00	106:55	Bus Reactor Hand tripped as per RLDC instruction due to voltage regulation.	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I	27-04-2023	10:21:00	27-04-2023	18:00:00	0:00	0:00	0:00	7:39	MPPTCL Taken the shutdown for Bay AMP Work.	
765kV Dhule(BDTCL) - Vadodara(PG)	29-04-2023	16:22:00	29-04-2023	18:58:00	0:00	0:00	2:36	0:00	Line tripped due to Kite threat struck into the earthwire and conductor & also due to bad weather condition line tripped on Ph-Ph-Earth Fault. Enclosed here with the photograph and newspaper cutting for reference.	

**Bhopal Dhule Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of April 2023**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

