

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of AUG 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765 KV Bus Reactor at BDTCL Dhule	16-08-2023	09:30:00	19-08-2023	21:51:00	0:00	0:00	0:00	84:21	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	100%
765 KV Bus Reactor at BDTCL Dhule	23-08-2023	09:50:00	30-08-2023	18:42:00	0:00	0:00	0:00	176:52	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	31-08-2023	09:47:00	31-08-2023	20:11:00	0:00	0:00	0:00	10:24	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No outages in this month	
400 KV Bus Reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765 kv Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 kv bus reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Indore LR at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765kV Dhule(BDTCL) - Vadodara(PG)					0:00	0:00	0:00	0:00	No outages in this month	
765KV S/C Aurangabad-Dhule Line					0:00	0:00	0:00	0:00	No outages in this month	
BHOPAL-INDORE 765 KV LINE					0:00	0:00	0:00	0:00	No outages in this month	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Aug 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of Aug 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

