

**Bhopal Dhule Transmission Company Limited**

**I. AC Transmission Line Outage Details for the month of FEB 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765 kv bus reactor at BDTCL Bhopal	01-02-2024	00:00:00	02-02-2024	22:02:00	0:00	0:00	0:00	46:02	Continuously in outage from previous month. Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	03-02-2024	07:39:00	04-02-2024	20:28:00	0:00	0:00	0:00	36:49	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	03-02-2024	07:47:00	03-02-2024	21:05:00	0:00	0:00	0:00	13:18	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	04-02-2024	10:32:00	04-02-2024	13:16:00	0:00	0:00	0:00	2:44	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	05-02-2024	11:03:00	07-02-2024	21:15:00	0:00	0:00	0:00	58:12	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	05-02-2024	11:08:00	06-02-2024	20:27:00	0:00	0:00	0:00	33:19	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	07-02-2024	09:14:00	08-02-2024	20:10:00	0:00	0:00	0:00	34:56	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	10-02-2024	10:41:00	10-02-2024	21:30:00	0:00	0:00	0:00	10:49	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	12-02-2024	09:28:00	13-02-2024	20:20:00	0:00	0:00	0:00	34:52	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	12-02-2024	08:52:00	13-02-2024	20:02:00	0:00	0:00	0:00	35:10	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	14-02-2024	09:36:00	14-02-2024	18:25:00	0:00	0:00	0:00	8:49	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	14-02-2024	09:18:00	15-02-2024	02:18:00	0:00	0:00	0:00	17:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	15-02-2024	09:38:00	16-02-2024	20:00:00	0:00	0:00	0:00	34:22	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	18-02-2024	08:01:00	18-02-2024	20:22:00	0:00	0:00	0:00	12:21	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765KV S/C Aurangabad-Dhule Line	18-02-2024	22:27:00	18-02-2024	22:27:00	0:00	0:00	0:00	0:00	Line A/R Successful due to transient R-phase to Earth Fault	
765 KV Bus Reactor at BDTCL Dhule	19-02-2024	07:01:00	21-02-2024	00:18:00	0:00	0:00	0:00	41:17	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	

**Bhopal Dhule Transmission Company Limited**

**I. AC Transmission Line Outage Details for the month of FEB 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765KV S/C Aurangabad-Dhule Line	19-02-2024	15:37:00	19-02-2024	18:58:00	0:00	0:00	0:00	3:21	BDTCL taken the emergency shutdown for removal of foreign material from span of T-332-333. This action follows routine ground patrolling to identify the causes of a successful A/R operation that occurred on 18.02.2024, aiming to prevent future abnormal operations or tripping due to the same cause. Enclosed here with the photograph for reference. Please consider this outage under deemed category because this is beyond the control of licensee.	
765 KV Bus Reactor at BDTCL Dhule	21-02-2024	08:57:00	21-02-2024	18:32:00	0:00	0:00	0:00	9:35	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	23-02-2024	08:38:00	23-02-2024	21:07:00	0:00	0:00	0:00	12:29	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	23-02-2024	08:43:00	26-02-2024	00:06:00	0:00	0:00	0:00	63:23	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	24-02-2024	09:33:00	25-02-2024	01:03:00	0:00	0:00	0:00	15:30	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	26-02-2024	07:46:00	26-02-2024	21:46:00	0:00	0:00	0:00	14:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	27-02-2024	08:02:00	27-02-2024	21:46:00	0:00	0:00	0:00	13:44	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
BHOPAL-INDORE 765 KV LINE	27-02-2024	09:23:00	27-02-2024	19:02:00	9:39	0:00	0:00	0:00	Outage availed for post monsoon maintenance work.	
765 kv bus reactor at BDTCL Bhopal	27-02-2024	08:06:00	01-03-2024	00:00:00	0:00	0:00	0:00	63:54	Bus reactor hand tripped as per RLDC instruction due to voltage regulation. <b>Still not charged in this month.</b>	
BHOPAL-INDORE 765 KV LINE	28-02-2024	09:11:00	28-02-2024	18:03:00	8:52	0:00	0:00	0:00	Outage availed for post monsoon maintenance work.	
765kV Dhule(BDTCL) - Vadodara(PG)					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line					0:00	0:00	0:00	0:00	No outages in this month	
765 kV Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400 KV Bus Reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Indore LR at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No outages in this month	

**Bhopal Dhule Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Feb 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of Feb 2024**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

