

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of May 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1	08-05-2023	08:25:00	08-05-2023	18:18:00	9:53	0:00	0:00	0:00	BDTCL taken the shutdown for Bay maintenance work. Shutdown taken at 08:25Hrs but E/S closed confirmation received from MSETCL at 09:40Hrs from remote end delayed due to Earth switch issue at MSETCL End. Charging clearance was given at 17:48Hrs and charging code from WRLDC received at 17:59Hrs , BDTCL considering addition 30min into BDTCL account from the charging clearance time, Delayed from MSETCL SS due to closure problem of the line isolator and bus isolator and line finally charged at 19:12 Hrs. Enclosed here with the email communication for reference.	99.95%
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1	08-05-2023	18:18:00	08-05-2023	19:20:00	0:00	1:02	0:00	0:00	Charging clearance was given at 17:48Hrs and charging code from WRLDC received at 17:59Hrs , BDTCL considering addition 30min into BDTCL account from the charging clearance time, Delayed from MSETCL SS due to closure problem of the line isolator and bus isolator and line finally charged at 19:12 Hrs. Enclosed here with the email communication for reference.	
765 kv bus reactor at BDTCL Bhopal	08-05-2023	09:04:00	29-05-2023	01:40:00	0:00	0:00	0:00	496:36	Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation.	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2	09-05-2023	10:06:00	09-05-2023	19:36:00	9:30	0:00	0:00	0:00	BDTCL taken the shutdown for Bay maintenance work. Shutdown taken at 10:06Hrs but E/S closed confirmation received from MSETCL at 11:15Hrs from remote end delayed due to unknown reason at MSETCL End.	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I	18-05-2023	10:35:00	18-05-2023	18:22:00	0:00	0:00	0:00	7:47	MPPTCL taken the shutdown for Bay maintenance work at MPPTCL SS.	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line	19-05-2023	10:43:00	19-05-2023	19:38:00	0:00	0:00	0:00	8:55	PGCIL taken the shutdown for Bay maintenance work at PGCIL Jabalpur SS.	
765kV Dhule(BDTCL) - Vadodara(PG)	28-05-2023	21:35:00	28-05-2023	23:19:00	0:00	0:00	1:44	0:00	Line Tripped due on transient fault due to inclement weather condition, BDTCL given the charging clearance at 22:49Hrs and WRLDC charging code received at 00:33Hrs on 29.05.2023 and line was finally charged at 00:40Hrs. BDTCL considered addition 30min into BDTCL account from the charging clearance time. Enclosed here with email communication for reference.	

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of May 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV Dhule(BDTCL) - Vadodara(PG)	28-05-2023	23:19:00	29-05-2023	00:40:00	0:00	0:00	0:00	1:21	BDTCL given the charging clearance at 22:49Hrs and WRLDC charging code received at 00:33Hrs on 29.05.2023 and line was finally charged at 00:40Hrs. BDTCL considered addition 30min into BDTCL account from the charging clearance time. Enclosed here with email communication for reference.	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

