

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|------------------------------------|------------|----------|-------------|----------|---|----------------|--|--------------------------|---|----------------|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 765 kv bus reactor at BDTCL Bhopal | 01-11-2023 | 09:19:00 | 09-11-2023 | 20:10:00 | 0:00 | 0:00 | 0:00 | 202:51 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | 100% |
| 765 KV Bus Reactor at BDTCL Dhule | 02-11-2023 | 10:33:00 | 02-11-2023 | 20:17:00 | 0:00 | 0:00 | 0:00 | 9:44 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 03-11-2023 | 09:21:00 | 03-11-2023 | 20:14:00 | 0:00 | 0:00 | 0:00 | 10:53 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 04-11-2023 | 10:14:00 | 04-11-2023 | 20:11:00 | 0:00 | 0:00 | 0:00 | 9:57 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 07-11-2023 | 08:30:00 | 07-11-2023 | 20:41:00 | 0:00 | 0:00 | 0:00 | 12:11 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 09-11-2023 | 08:34:00 | 09-11-2023 | 20:03:00 | 0:00 | 0:00 | 0:00 | 11:29 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 10-11-2023 | 08:41:00 | 10-11-2023 | 18:21:00 | 0:00 | 0:00 | 0:00 | 9:40 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 kv bus reactor at BDTCL Bhopal | 10-11-2023 | 08:31:00 | 10-11-2023 | 19:51:00 | 0:00 | 0:00 | 0:00 | 11:20 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 11-11-2023 | 09:40:00 | 11-11-2023 | 20:03:00 | 0:00 | 0:00 | 0:00 | 10:23 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 kv bus reactor at BDTCL Bhopal | 13-11-2023 | 08:16:00 | 16-11-2023 | 20:19:00 | 0:00 | 0:00 | 0:00 | 84:03 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 14-11-2023 | 07:52:00 | 14-11-2023 | 21:52:00 | 0:00 | 0:00 | 0:00 | 14:00 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 15-11-2023 | 07:42:00 | 15-11-2023 | 20:38:00 | 0:00 | 0:00 | 0:00 | 12:56 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 16-11-2023 | 10:52:00 | 16-11-2023 | 19:52:00 | 0:00 | 0:00 | 0:00 | 9:00 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 17-11-2023 | 09:24:00 | 17-11-2023 | 20:32:00 | 0:00 | 0:00 | 0:00 | 11:08 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 kv bus reactor at BDTCL Bhopal | 17-11-2023 | 09:21:00 | 17-11-2023 | 21:26:00 | 0:00 | 0:00 | 0:00 | 12:05 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 18-11-2023 | 07:42:00 | 18-11-2023 | 20:22:00 | 0:00 | 0:00 | 0:00 | 12:40 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 kv bus reactor at BDTCL Bhopal | 18-11-2023 | 07:19:00 | 21-11-2023 | 21:42:00 | 0:00 | 0:00 | 0:00 | 86:23 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 19-11-2023 | 08:15:00 | 19-11-2023 | 19:41:00 | 0:00 | 0:00 | 0:00 | 11:26 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 20-11-2023 | 08:47:00 | 20-11-2023 | 17:59:00 | 0:00 | 0:00 | 0:00 | 9:12 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 21-11-2023 | 09:13:00 | 21-11-2023 | 17:50:00 | 0:00 | 0:00 | 0:00 | 8:37 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|---|------------|----------|-------------|----------|---|----------------|--|--------------------------|---|----------------|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 765 kv bus reactor at BDTCL Bhopal | 22-11-2023 | 07:07:00 | 23-11-2023 | 02:23:00 | 0:00 | 0:00 | 0:00 | 19:16 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 22-11-2023 | 06:58:00 | 22-11-2023 | 20:51:00 | 0:00 | 0:00 | 0:00 | 13:53 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 23-11-2023 | 09:13:00 | 23-11-2023 | 19:43:00 | 0:00 | 0:00 | 0:00 | 10:30 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 kv bus reactor at BDTCL Bhopal | 23-11-2023 | 09:02:00 | 24-11-2023 | 20:21:00 | 0:00 | 0:00 | 0:00 | 35:19 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 24-11-2023 | 08:24:00 | 24-11-2023 | 19:36:00 | 0:00 | 0:00 | 0:00 | 11:12 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 25-11-2023 | 07:55:00 | 25-11-2023 | 20:32:00 | 0:00 | 0:00 | 0:00 | 12:37 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 kv bus reactor at BDTCL Bhopal | 25-11-2023 | 07:51:00 | 26-11-2023 | 21:21:00 | 0:00 | 0:00 | 0:00 | 37:30 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| 765 KV Bus Reactor at BDTCL Dhule | 26-11-2023 | 09:58:00 | 26-11-2023 | 18:40:00 | 0:00 | 0:00 | 0:00 | 8:42 | Bus reactor hand tripped as per RLDC instruction due to voltage regulation. | |
| BHOPAL-INDORE 765 KV LINE | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765kv Dhule(BDTCL) - Vadodara(PG) | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765/400 KV ICT 1 at BDTCL Bhopal | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765KV S/C Aurangabad-Dhule Line | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765 KV Aurangabad Line Reactor at BDTCL Dhule | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 400 kv Bhopal(BDTCL) -Bhopal(MPPTCL) I | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 400 kv Bhopal(BDTCL) -Bhopal(MPPTCL) II | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765/400 KV ICT 2 at BDTCL Bhopal | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 400 KV Bus Reactor at BDTCL Bhopal | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765 kv Bhopal-Jabalpur LR at Bhopal | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765 KV Indore LR at BDTCL Bhopal | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765/400 KV ICT 1 at BDTCL Dhule | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765/400 KV ICT 2 at BDTCL Dhule | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 400KV Dhule(BDTCL)-Dhule MSETCL CKT-1 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 400KV Dhule(BDTCL)-Dhule MSETCL CKT-2 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |
| 765 KV Vadodara Line Reactor at BDTCL Dhule | | | | | 0:00 | 0:00 | 0:00 | 0:00 | No outages in this month | |

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Nov 2023

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |
| Nil | Nil | Nil |

III. Details of compensation paid by the inter-State transmission licensee for the month of Nov 2023

Schedule III

| Element Name | Violation of Regulation 5(a) | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|------------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |

