

**Bhopal Dhule Transmission Company Limited**

**I. AC Transmission Line Outage Details for the month of OCT 2023**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
BHOPAL-INDORE 765 KV LINE	09-10-2023	10:56:00	09-10-2023	18:57:00	0:00	0:00	0:00	8:01	PGCIL taken the shutdown for AMP works of Line Terminal Equipments & Line Reactor.	100%
765 KV Bus Reactor at BDTCL Dhule	16-10-2023	11:42:00	19-10-2023	20:32:00	0:00	0:00	0:00	80:50	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	17-10-2023	11:48:00	24-10-2023	20:20:00	0:00	0:00	0:00	176:32	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	23-10-2023	10:23:00	26-10-2023	17:09:00	0:00	0:00	0:00	78:46	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
BHOPAL-INDORE 765 KV LINE	25-10-2023	18:31:00	25-10-2023	19:29:00	0:00	0:00	0:00	0:58	PGCIL taken the emergency shutdown due to sparking observed at Neutral CT (Terminal Connector) of Line Reactor at Indore SS end.	
765 kv bus reactor at BDTCL Bhopal	25-10-2023	09:05:00	28-10-2023	22:03:00	0:00	0:00	0:00	84:58	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	27-10-2023	09:21:00	29-10-2023	21:53:00	0:00	0:00	0:00	60:32	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Dhule(BDTCL) - Vadodara(PG)					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765KV S/C Aurangabad-Dhule Line					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line					0:00	0:00	0:00	0:00	No outages in this month	
400 KV Bus Reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 kv Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Indore LR at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	

**Bhopal Dhule Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Oct 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of Oct 2023**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

