

**Bhopal Dhule Transmission Company Limited**

**I. AC Transmission Line Outage Details for the month of SEP 2023**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765 KV Bus Reactor at BDTCL Dhule	01-09-2023	10:40:00	01-09-2023	20:02:00	0:00	0:00	0:00	9:22	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	99.73%
765 KV Bus Reactor at BDTCL Dhule	06-09-2023	11:15:00	07-09-2023	03:33:00	0:00	0:00	0:00	16:18	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Dhule(BDTCL) - Vadodara(PG)	10-09-2023	09:20:00	10-09-2023	10:32:00	0:00	1:12	0:00	0:00	BDTCL taken the emergency shutdown for replacement of Y-phase damaged insulator at Tower No 544. Shutdown was taken at 09:20Hrs however PTW for the same was issued by PGCIL at 10:32Hrs due to unknown reason, enclosed here with the email communication for reference. Kindly consider the this outage period into others account.	
765kV Dhule(BDTCL) - Vadodara(PG)	10-09-2023	10:32:00	10-09-2023	20:03:00	9:31	0:00	0:00	0:00	BDTCL taken the emergency shutdown for insulator replacement work at Tower No. 544. PTW for the same was issued at 10:32Hrs. Charging clearance was given at 19:08Hrs and charging code was received at 19:14Hrs and line was finally charged at 20:03Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason at Vadodara end enclosed here with the email copy.	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line	15-09-2023	16:04:00	15-09-2023	16:04:00	0:00	0:00	0:00	0:00	Auto Reclosure Successful due to transient fault, R-phase to earth fault.	
765/400 KV ICT 1 at BDTCL Bhopal	21-09-2023	08:50:00	21-09-2023	22:49:00	13:59	0:00	0:00	0:00	BDTCL taken the shutdown for AMP work.	
400 KV Bus Reactor at BDTCL Bhopal	22-09-2023	10:39:00	22-09-2023	16:38:00	5:59	0:00	0:00	0:00	BDTCL taken the shutdown for AMP work.	
765KV S/C Aurangabad-Dhule Line					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 kv bus reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
BHOPAL-INDORE 765 KV LINE					0:00	0:00	0:00	0:00	No outages in this month	
765 kv Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Indore LR at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	

**Bhopal Dhule Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Sep 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of Sep 2023**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

