

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of JUL 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	01-07-2023	00:00:00	01-08-2023	00:00:00	0:00	0:00	0:00	744:00	Continuously in outage from June-23 month, Line hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	100.00%
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	05-07-2023	19:43:00	05-07-2023	19:43:00	0:00	0:00	0:00	A/R was successfully due to transient R-Phase to Earth Fault.		
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	21-07-2023	18:59:00	21-07-2023	18:59:00	0:00	0:00	0:00	A/R was successfully due to transient R-Phase to Earth Fault.		

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JUL 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JUL 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

