

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of MAY 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	27-05-2023	15:46:00	27-05-2023	18:49:00	0:00	0:00	3:03	0:00	Line tripped on Ph to Ph transient fault due to inclement weather condition and also due to foreign material came in contact with the line which causes tripping, this is for the information that the said line is double circuit line and Ph to Ph fault was happened due to transient fault, JTCL given the charging clearance at 18:27Hrs, charging code received at 18:46Hrs and charging attempt was taken at 18:49Hrs but line again tripped due to overvoltage protection operated. Line finally charged at 19:50Hrs. Enclosed here with the email communication and newspaper cutting for your refrence.	99.83%
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	27-05-2023	18:49:00	27-05-2023	19:50:00	0:00	0:00	1:01	0:00	During charging attempt the line tripped on Overvoltage at 18:49Hrs and line was finally charged at 19:50Hrs. Enclosed here with the email communication.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	02-05-2023	00:52:00	02-05-2023	00:52:00	0:00	0:00	0:00	0:00	A/R was successfully due to transient Y-Phase to Earth Fault.	

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

