

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	11-01-2023	00:00:00	27-11-2023	20:35:00	0:00	0:00	0:00	644:35	Continuously in outage since last month. Line hand tripped as per RLDC instruction due to voltage regulation.	100.00%
765kV JTCL Dharamjaygarh-Jabalpur CKT-3					0:00	0:00	0:00	0:00	No outages in this month	
765kV Jabalpur-Bina III					0:00	0:00	0:00	0:00	No outages in this month	

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of NOV 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of NOV 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

