

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of OCT 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	01-10-2023	04:44:00	10-10-2023	11:31:00	0:00	0:00	0:00	222:47	Line hand tripped as per RLDC instruction due to voltage regulation.	100.00%
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	16-10-2023	19:38:00	01-11-2023	00:00:00	0:00	0:00	0:00	364:22	Line hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	
765kV Jabalpur-Bina III	25-10-2023	11:43:00	25-10-2023	22:21:00	0:00	0:00	0:00	10:38	PGCIL taken the shutdown for taking spare reactor in place of B-phase. Only Line portion belong to JTCL.	

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCT 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of OCT 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

