

Khargone Transmission Limited

I. AC Transmission Line Outage Details for the month of April 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS	11-04-2023	11:20:00	11-04-2023	15:48:00	0:00	0:00	0:00	4:28	Shutdown taken for switching operation for taking the Spare Phase into service & R-phase as a standby. As per CEA regulation to ensure hotspare healthiness, in every 6 months switching operation was carried out. As per 540OCC for reactor switching 5hrs period will be considered under deemed availability. No maintenance activity was done.	99.33%
765KV-Dhule-Khandwa-Sterlite-1	23-04-2023	8:42:00	23-04-2023	19:10:00	10:28	0:00	0:00	0:00	KTL taken the shutdown for tower and cross arm strengthening work.	
765KV-Dhule-Khandwa-Sterlite-2	24-04-2023	08:31:00	24-04-2023	18:51:00	10:20	0:00	0:00	0:00	KTL taken the shutdown for tower and cross arm strengthening work.	
400kV Khargone(NTPC)-Rajgarh Line	26-04-2023	17:33:00	26-04-2023	18:59:00	0:00	1:26	0:00	0:00	Line tripped due to B-Phase to Earth Fault at fault distance of 33kms from Khargone SS. Only LLO portion belongs to KTL having the line length of 7Kms. Fault location is beyond the ownership of KTL.	
765KV-Indore-Khandwa-Sterlite-1	27-04-2023	08:08:00	27-04-2023	18:28:00	10:20	0:00	0:00	0:00	KTL taken the shutdown for tower and cross arm strengthening work. Charging clearance was given at 17:58Hrs,chargig code was received at 18:26Hrs and line was finally charged at 18:55Hrs. KTL considered additional 30min from charging clearance into the account. Kindly consider addition ouatge period under Deemed category.	
765KV-Indore-Khandwa-Sterlite-1	27-04-2023	18:28:00	27-04-2023	18:55:00	0:00	0:00	0:00	0:27	Charging clearance was given at 17:58Hrs,chargig code was received at 18:26Hrs and line was finally charged at 18:55Hrs. KTL considered additional 30min from charging clearance into the account. Kindly consider addition ouatge period under Deemed category. Enclosed here with the email communication for your reference.	
765KV-Indore-Khandwa-Sterlite-2	29-04-2023	08:41:00	29-04-2023	18:26:00	9:45	0:00	0:00	0:00	KTL taken the shutdown for tower and cross arm strengthening work. Charging clearance was given at 17:56Hrs,chargig code was received at 19:11Hrs and line was finally charged at 19:39Hrs. KTL considered additional 30min from charging clearance into the account. Kindly consider addition ouatge period under Deemed category.	
765KV-Indore-Khandwa-Sterlite-2	29-04-2023	18:26:00	29-04-2023	19:39:00	0:00	0:00	0:00	1:13	Charging clearance was given at 17:56Hrs,chargig code was received at 19:11Hrs and line was finally charged at 19:39Hrs. KTL considered additional 30min from charging clearance into the account. Kindly consider addition ouatge period under Deemed category. Enclosed here with the email communication for your reference.	

Khargone Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

