

Khargone Transmission Limited

I. AC Transmission Line Outage Details for the month of DEC 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Khandwa-KTL-BR-1 at Khandwa SS	01-12-2023	00:00:00	04-12-2023	05:20:00	0:00	0:00	0:00	77:20	Continuously in outage from last month. Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	100.00%
765kV Khandwa-KTL-BR-1 at Khandwa SS	04-12-2023	07:51:00	11-12-2023	02:26:00	0:00	0:00	0:00	162:35	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	12-12-2023	08:03:00	12-12-2023	20:40:00	0:00	0:00	0:00	12:37	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	13-12-2023	07:39:00	17-12-2023	19:23:00	0:00	0:00	0:00	107:44	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	18-12-2023	10:29:00	18-12-2023	20:23:00	0:00	0:00	0:00	9:54	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	21-12-2023	10:41:00	31-12-2023	23:14:00	0:00	0:00	0:00	252:33	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765KV-Dhule-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khargone(NTPC)-Rajgarh Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-Khargone(NTPC) Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

Khargone Transmission Limited**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of DEC 2023****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of DEC 2023**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

