

**Khargone Transmission Limited**

**I. AC Transmission Line Outage Details for the month of FEB 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Khandwa-KTL-BR-1 at Khandwa SS	01-02-2024	00:00:00	02-02-2024	21:45:00	0:00	0:00	0:00	45:45	Continuously in outage from previous month. Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV Khandwa-Khargone(NTPC) Line	12-02-2024	09:27:00	12-02-2024	21:46:00	0:00	12:19	0:00	0:00	Shutdown availed by Powergrid WR-2 for maintenance work.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	03-02-2024	10:37:00	21-02-2024	20:15:00	0:00	0:00	0:00	441:38	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	22-02-2024	09:16:00	22-02-2024	21:25:00	0:00	0:00	0:00	12:09	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	24-02-2024	09:43:00	26-02-2024	22:18:00	0:00	0:00	0:00	60:35	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	27-02-2024	10:02:00	01-03-2024	00:00:00	0:00	0:00	0:00	61:58	Bus reactor hand tripped as per RLDC instruction due to voltage regulation. <b>Still not charged in this month.</b>	
765KV-Dhule-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khargone(NTPC)-Rajgarh Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of FEB 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of FEB 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

