

Khargone Transmission Limited

I. AC Transmission Line Outage Details for the month of JAN 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Khandwa-KTL-BR-1 at Khandwa SS	02-01-2024	10:28:00	05-01-2024	21:00:00	0:00	0:00	0:00	82:32	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	06-01-2024	09:32:00	07-01-2024	22:01:00	0:00	0:00	0:00	36:29	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV Khandwa-Khargone(NTPC) Line	08-01-2024	11:17:00	08-01-2024	20:24:00	0:00	9:07	0:00	0:00	Shutdown availed by Powergrid WR-2 for shut-down nature defect attending work for the Portion owned by PGCIL.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	13-01-2024	07:28:00	01-02-2024	00:00:00	0:00	0:00	0:00	448:32	Bus reactor hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	
765KV-Dhule-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khargone(NTPC)-Rajgarh Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

Khargone Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JAN 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JAN 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

