

Khargone Transmission Limited

I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Khandwa-KTL-BR-1 at Khandwa SS	01-11-2023	00:00:00	09-11-2023	04:04:00	0:00	0:00	0:00	196:04	Continuously in outage from last month. Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	99.96%
765kV Khandwa-KTL-BR-1 at Khandwa SS	09-11-2023	10:21:00	10-11-2023	18:49:00	0:00	0:00	0:00	32:28	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	16-11-2023	10:54:00	16-11-2023	20:40:00	0:00	0:00	0:00	9:46	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	18-11-2023	07:31:00	18-11-2023	20:35:00	0:00	0:00	0:00	13:04	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	19-11-2023	10:22:00	19-11-2023	20:16:00	0:00	0:00	0:00	9:54	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	21-11-2023	09:56:00	21-11-2023	20:26:00	0:00	0:00	0:00	10:30	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	23-11-2023	09:30:00	23-11-2023	21:50:00	0:00	0:00	0:00	12:20	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	24-11-2023	10:34:00	24-11-2023	20:42:00	0:00	0:00	0:00	10:08	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765KV-Dhule-Khandwa-Sterlite-1	26-11-2023	14:55:00	26-11-2023	16:42:00	1:47	0:00	0:00	0:00	Line tripped due to B-phase to earth fault	
400kV Khargone(NTPC)-Rajgarh Line	26-11-2023	14:28:00	27-11-2023	12:48:00	0:00	22:20	0:00	0:00	Tripped due Y-phase to earth fault. As per fault location, distance is 110 km from Khargone (NTPC) end and 34 km from Rajgarh end. KHTL's ownership is till 6.787 kms upto LILO portion.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	30-11-2023	10:06:00	01-12-2023	00:00:00	0:00	0:00	0:00	13:54	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-Khargone(NTPC) Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

Khargone Transmission Limited**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of NOV 2023****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of NOV 2023**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

