

RAPP Transmission Company Limited

I. AC Transmission Line Outage Details for the month of October 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400kV RAPP-Sujalpur Ckt-1	30-10-2023	10:55:00	30-10-2023	20:23:00	0:00	0:00	0:00	9:28	Line shutdown taken for construction activities of new system being executed by Rajgarh Transmission Limited for the Stringing Work of the 400 KV Pachora-Bhopal under construction Line. Enclosed here with the shutdown request letter from the agency for reference purpose.	100.00%
400kV RAPP-Sujalpur Ckt-2	30-10-2023	11:01:00	30-10-2023	20:43:00	0:00	0:00	0:00	9:42	Line shutdown taken for construction activities of new system being executed by Rajgarh Transmission Limited for the Stringing Work of the 400 KV Pachora-Bhopal under construction Line. Enclosed here with the shutdown request letter from the agency for reference purpose.	
400kV RAPP-Sujalpur Ckt-2	04-10-2023	13:24:00	04-10-2023	13:24:00	0:00	0:00	0:00	0:00	A/R successful due to transient B-phase to Earth fault FL from Shujalpur is 90Kms & FC is 3.08KA FL from RAPP is 102Kms & FC is 2.97KA	

RAPP Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of October 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of October 2023

Schedule III

Element Name	violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

