

Ishanagar Power Transmission Limited

Amendment No. - 03 (Pre Bid Clarifications)

12.03.2026

Subject: Implementation of 1 No. of 400kV line bay at Ishanagar (New) S/s for interconnection of M/s Avaada Energy Pvt. Ltd. (AEPL) 350 MW REGS

Sl. No	Name of Document	Existing Provision/Extract from Specification	Suggested texts for amendments/Query/Clarification Sought	Rationale for Clarification/Amendments	IPTL Replies
1	Indicative Items For Electrical Works- Ishanagar- RTM ,Volume II	As per Line Item- P, Switchyard Mandatory Spares in remarks it has been mentioned - One Spare for complete package	Bidder understanding is 1 No. Spares to be considered for CT,CVT,WT,BPI etc. Accordingly, spares to be considered for 400kV CB, Isolators & Control & Relay Panel. Please Confirm		Please consider as per CEA Mandatory Spare list.